

Licensee:

SUEZ WATER PTY LIMITED
 PO BOX 6059

WETHERILL PARK NSW 2164

POINT 1 Monthly Summary

Note: does not include any monitoring conducted prior to 31 March 2012.

Month	Pollutant	Units of Measure	Monitoring Frequency	No. of Time Measured During Current Month	Min. Value	Average value	Max. Value	100 percentile Concentration Limit
Apr-12	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	2.59	4.76	9.46	50
	pH	pH	Daily during any discharge	4	7.88	8.20	8.5	6.5-8.5
May-12	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2.73	3.95	5.16	50
	pH	pH	Daily during any discharge	2	7.94	8.09	8.24	6.5-8.5
Jun-12	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	7.25	20	50
	pH	pH	Daily during any discharge	4	7.39	7.74	7.96	6.5-8.5
Jul-12	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	4	4	4	50
	pH	pH	Daily during any discharge	1	7.27	7.27	7.27	6.5-8.5
Aug-12	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2	2	2	50
	pH	pH	Daily during any discharge	2	7.45	7.71	7.97	6.5-8.5
Sep-12	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	4	7	50
	pH	pH	Daily during any discharge	2	7.55	7.66	7.77	6.5-8.5
Oct-12	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	2	19.25	37	50
	pH	pH	Daily during any discharge	4	6.67	7.24	7.66	6.5-8.5
Nov-12	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	3	4.3	6	50
	pH	pH	Daily during any discharge	3	7.69	7.76	7.79	6.5-8.5
Dec-12	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.3	5	50
	pH	pH	Daily during any discharge	3	7.25	8.0	8.48	6.5-8.5
Jan-13	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.5	2	50
	pH	pH	Daily during any discharge	2	8.17	8.3	8.35	6.5-8.5
Feb-13	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	4.0	5	50
	pH	pH	Daily during any discharge	2	8.45	8.48	8.5	6.5-8.5
Mar-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	9.0	22	50
	pH	pH	Daily during any discharge	3	8.28	8.36	8.45	6.5-8.5
Apr-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	3	6.0	10	50
	pH	pH	Daily during any discharge	3	7.56	8.01	8.36	6.5-8.5
May-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	3	5.0	8	50
	pH	pH	Daily during any discharge	3	7.64	7.78	7.96	6.5-8.5
Jun-13	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	1	5.3	10	50
	pH	pH	Daily during any discharge	5	7.67	7.99	8.42	6.5-8.5

Jul-13	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	2.0	3	50
	pH	pH	Daily during any discharge	2	8.17	8.30	8.43	6.5-8.5
Aug-13	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	4	5.0	6	50
	pH	pH	Daily during any discharge	2	7.64	7.83	8.02	6.5-8.5
Sep-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	0.5	2.2	5	50
	pH	pH	Daily during any discharge	3	7.81	8.08	8.45	6.5-8.5
Oct-13	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	5	5.5	6	50
	pH	pH	Daily during any discharge	2	7.61	7.69	7.76	6.5-8.5
Nov-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	7	25.0	38	50
	pH	pH	Daily during any discharge	3	7.68	8.19	8.47	6.5-8.5
Dec-13	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	2	5.0	10	50
	pH	pH	Daily during any discharge	3	6.81	7.60	8.35	6.5-8.5
Jan-14	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.0	3	50
	pH	pH	Daily during any discharge	3	7.96	8.16	8.32	6.5-8.5
Feb-14	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	1	3.2	7	50
	pH	pH	Daily during any discharge	5	6.71	7.53	8.48	6.5-8.5
Mar-14	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	1	3.0	6	50
	pH	pH	Daily during any discharge	5	6.64	7.29	7.93	6.5-8.5
Apr-14	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	1	3.7	11	50
	pH	pH	Daily during any discharge	6	6.95	7.48	8.19	6.5-8.5
May-14	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	0.5	1.8	6	50
	pH	pH	Daily during any discharge	6	6.57	7.34	7.67	6.5-8.5
Jun-14	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	0.5	1.3	3	50
	pH	pH	Daily during any discharge	6	7.18	7.57	7.91	6.5-8.5
Jul-14	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.0	1	50
	pH	pH	Daily during any discharge	3	7.58	8.00	8.37	6.5-8.5
Aug-14	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	8.5	23	50
	pH	pH	Daily during any discharge	4	6.62	7.97	8.47	6.5-8.5
Sep-14	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	5	5.0	5	50
	pH	pH	Daily during any discharge	1	7.92	7.92	7.92	6.5-8.5
Oct-14	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	28	28.0	28	50
	pH	pH	Daily during any discharge	1	6.99	6.99	6.99	6.5-8.5
Nov-14	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	4.0	5	50
	pH	pH	Daily during any discharge	2	6.69	7.41	8.12	6.5-8.5
Dec-14	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	2	18.7	28	50
	pH	pH	Daily during any discharge	3	6.56	7.42	8.23	6.5-8.5
	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A

Jan-15	Total suspended solids	milligrams per litre	Daily during any discharge	3	0.5	4.5	10	50
	pH	pH	Daily during any discharge	3	7.37	7.83	8.09	6.5-8.5
Feb-15	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	2	2.0	2	50
	pH	pH	Daily during any discharge	1	8.1	8.10	8.1	6.5-8.5
Mar-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	3.5	4	50
	pH	pH	Daily during any discharge	2	8.25	8.31	8.37	6.5-8.5
Apr-15	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	3	12.8	23	50
	pH	pH	Daily during any discharge	5	8.03	8.33	8.43	6.5-8.5
May-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	3.5	4	50
	pH	pH	Daily during any discharge	2	6.66	7.29	7.92	6.5-8.5
Jun-15	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	6	8	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	5.7	11	50
	pH	pH	Daily during any discharge	3	7.52	8.03	8.34	6.5-8.5
Jul-15	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	6	6.0	6	50
	pH	pH	Daily during any discharge	1	7.96	7.96	7.96	6.5-8.5
Aug-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	10.0	19	50
	pH	pH	Daily during any discharge	2	7.37	7.76	8.14	6.5-8.5
Sep-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	2.0	3	50
	pH	pH	Daily during any discharge	2	8.05	8.26	8.47	6.5-8.5
Oct-15	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	8.5	12	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	3	5.7	8	50
	pH	pH	Daily during any discharge	3	7.22	7.68	7.97	6.5-8.5
Nov-15	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	8.0	26	50
	pH	pH	Daily during any discharge	4	8.42	8.44	8.46	6.5-8.5
Dec-15	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	3.3	5.5	50
	pH	pH	Daily during any discharge	2	7.01	7.69	8.37	6.5-8.5
Jan-16	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	4.8	10	50
	pH	pH	Daily during any discharge	4	7.90	8.04	8.25	6.5-8.5
Feb-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	38.5	72	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	5.5	8	50
	pH	pH	Daily during any discharge	2	7.91	8.04	8.16	6.5-8.5
Mar-16	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	1	1.0	1	50
	pH	pH	Daily during any discharge	1	8.04	8.04	8.04	6.5-8.5
Apr-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.0	1	50
	pH	pH	Daily during any discharge	2	8.01	8.07	8.12	6.5-8.5
May-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.0	1	50
	pH	pH	Daily during any discharge	2	7.23	7.56	7.89	6.5-8.5
Jun-16	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	8.4	27	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	15.3	27	50
	pH	pH	Daily during any discharge	4	7.09	7.68	8.17	6.5-8.5
Jul-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2	4.5	7	50

	pH	pH	Daily during any discharge	2	7.90	8.04	8.17	6.5-8.5
Aug-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	2.0	3	50
	pH	pH	Daily during any discharge	2	8.35	8.35	8.35	6.5-8.5
Sep-16	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	6	6.0	6	50
	pH	pH	Daily during any discharge	1	8.23	8.23	8.23	6.5-8.5
Oct-16	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	2	2.0	2	50
	pH	pH	Daily during any discharge	1	8.37	8.37	8.37	6.5-8.5
Nov-16	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	4.5	8	50
	pH	pH	Daily during any discharge	2	8.25	8.27	8.29	6.5-8.5
Dec-16	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	2	4.0	6	50
	pH	pH	Daily during any discharge	3	7.46	7.95	8.22	6.5-8.5
Jan-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	2.0	3	50
	pH	pH	Daily during any discharge	2	8.35	8.36	8.36	6.5-8.5
Feb-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	9.0	17	50
	pH	pH	Daily during any discharge	2	7.76	8.06	8.35	6.5-8.5
Mar-17	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	20.8	38	50
	pH	pH	Daily during any discharge	4	7.78	8.01	8.29	6.5-8.5
Apr-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	6.5	12	50
	pH	pH	Daily during any discharge	2	7.42	7.59	7.75	6.5-8.5
May-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.5	2	50
	pH	pH	Daily during any discharge	2	7.48	7.85	8.21	6.5-8.5
Jun-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	5	6.0	7	50
	pH	pH	Daily during any discharge	2	7.77	8.06	8.35	6.5-8.5
Jul-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2	3.0	4	50
	pH	pH	Daily during any discharge	2	8.17	8.33	8.49	6.5-8.5
Aug-17	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.5	2	50
	pH	pH	Daily during any discharge	3	8.09	8.22	8.29	6.5-8.5
Sep-17	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	2	2.0	2	50
	pH	pH	Daily during any discharge	1	8.47	8.47	8.47	6.5-8.5
Oct-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	2.5	4.0	5.5	50
	pH	pH	Daily during any discharge	2	7.70	8.07	8.44	6.5-8.5
Nov-17	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.0	1	50
	pH	pH	Daily during any discharge	2	8.11	8.14	8.16	6.5-8.5
Dec-17	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.0	1	50
	pH	pH	Daily during any discharge	3	7.76	8.08	8.26	6.5-8.5
Jan-18	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.5	2.5	50
	pH	pH	Daily during any discharge	3	7.89	8.00	8.16	6.5-8.5

Feb-18	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	3.8	6.5	50
	pH	pH	Daily during any discharge	2	7.56	7.86	8.16	6.5-8.5
Mar-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	2.4	4	50
	pH	pH	Daily during any discharge	4	7.33	7.91	8.29	6.5-8.5
Apr-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1.2	2.2	4	50
	pH	pH	Daily during any discharge	4	8.03	8.27	8.46	6.5-8.5
May-18	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.8	3	50
	pH	pH	Daily during any discharge	3	8.02	8.24	8.43	6.5-8.5
Jun-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	0.56	3.8	7.8	50
	pH	pH	Daily during any discharge	4	8.00	8.18	8.35	6.5-8.5
Jul-18	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.5	2	50
	pH	pH	Daily during any discharge	2	7.66	8.07	8.48	6.5-8.5
Aug-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	2.0	5	50
	pH	pH	Daily during any discharge	4	7.66	7.95	8.18	6.5-8.5
Sep-18	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.3	4	50
	pH	pH	Daily during any discharge	3	7.94	7.99	8.06	6.5-8.5
Oct-18	Oil and Grease	milligrams per litre	Daily during any discharge	10	<5	5.60	11	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	10	1	8.5	44	50
	pH	pH	Daily during any discharge	10	7.36	8.14	8.47	6.5-8.5
Nov-18	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	2	4.3	8	50
	pH	pH	Daily during any discharge	4	7.77	8.17	8.47	6.5-8.5
Dec-18	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	5	11.0	20	50
	pH	pH	Daily during any discharge	3	6.83	7.86	8.40	6.5-8.5
Jan-19	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	5.4	16	50
	pH	pH	Daily during any discharge	4	7.14	7.96	8.43	6.5-8.5
Feb-19	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.3	4	50
	pH	pH	Daily during any discharge	3	8.02	8.30	8.47	6.5-8.5
Mar-19	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	14.3	23	50
	pH	pH	Daily during any discharge	4	7.86	8.12	8.32	6.5-8.5
Apr-19	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.3	4	50
	pH	pH	Daily during any discharge	3	7.91	8.10	8.46	6.5-8.5
May-19	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.7	3	50
	pH	pH	Daily during any discharge	3	6.99	7.73	8.12	6.5-8.5
Jun-19	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	3	5.0	7	50
	pH	pH	Daily during any discharge	3	8.01	8.17	8.38	6.5-8.5
Jul-19	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	2	3.2	5	50
	pH	pH	Daily during any discharge	3	7.85	8.10	8.28	6.5-8.5

Aug-19	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.3	5	50
	pH	pH	Daily during any discharge	3	7.57	7.90	8.19	6.5-8.5
Sep-19	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	4	9.7	18	50
	pH	pH	Daily during any discharge	3	7.14	7.76	8.47	6.5-8.5
Oct-19	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3	9.0	15	50
	pH	pH	Daily during any discharge	2	7.56	7.91	8.25	6.5-8.5
Nov-19	Oil and Grease	milligrams per litre	Daily during any discharge	1	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	1	3	3.0	3	50
	pH	pH	Daily during any discharge	1	8.45	8.45	8.45	6.5-8.5
Dec-19	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.0	1	50
	pH	pH	Daily during any discharge	2	7.03	7.57	8.10	6.5-8.5
Jan-20	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.0	4	50
	pH	pH	Daily during any discharge	3	6.90	7.85	8.34	6.5-8.5
Feb-20	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	2	18.3	35	50
	pH	pH	Daily during any discharge	6	7.44	7.89	8.32	6.5-8.5
Mar-20	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	6	7	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	2	2.3	3	50
	pH	pH	Daily during any discharge	3	7.23	7.92	8.32	6.5-8.5
Apr-20	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	1.0	1	50
	pH	pH	Daily during any discharge	2	7.62	7.65	7.68	6.5-8.5
May-20	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	3.5	9.7	15.9	50
	pH	pH	Daily during any discharge	2	6.68	7.00	7.31	6.5-8.5
Jun-20	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.2	3.5	50
	pH	pH	Daily during any discharge	3	7.37	7.72	8.11	6.5-8.5
Jul-20	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	6	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	4	9.3	18	50
	pH	pH	Daily during any discharge	3	7.66	7.88	8.28	6.5-8.5
Aug-20	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	4	11.3	24	50
	pH	pH	Daily during any discharge	3	7.23	7.87	8.41	6.5-8.5
Sep-20	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	6	7.5	9	50
	pH	pH	Daily during any discharge	2	8.37	8.39	8.41	6.5-8.5
Oct-20	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	2	4.0	6	50
	pH	pH	Daily during any discharge	4	7.44	8.04	8.47	6.5-8.5
Nov-20	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.7	3	50
	pH	pH	Daily during any discharge	3	7.97	8.14	8.24	6.5-8.5
Dec-20	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	2	13.2	31	50
	pH	pH	Daily during any discharge	5	7.55	7.96	8.22	6.5-8.5
Jan-21	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	3.5	7	50
	pH	pH	Daily during any discharge	4	7.38	7.81	8.03	6.5-8.5
	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	5.33	6	N/A

Feb-21	Total suspended solids	milligrams per litre	Daily during any discharge	3	2	8.0	17	50
	pH	pH	Daily during any discharge	3	7.48	8.02	8.37	6.5-8.5
Mar-21	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	7.00	11	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	4	12.4	22	50
	pH	pH	Daily during any discharge	5	7.18	7.49	7.95	6.5-8.5
Apr-21	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	1.7	3	50
	pH	pH	Daily during any discharge	3	7.36	7.76	8.08	6.5-8.5
May-21	Oil and Grease	milligrams per litre	Daily during any discharge	2	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	2	1	3.0	5	50
	pH	pH	Daily during any discharge	2	7.56	7.63	7.70	6.5-8.5
Jun-21	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	5.00	6	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	2	4.3	6	50
	pH	pH	Daily during any discharge	4	6.90	7.70	8.33	6.5-8.5
Jul-21	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	5.00	5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.8	4	50
	pH	pH	Daily during any discharge	3	7.40	7.72	8.11	6.5-8.5
Aug-21	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	5.75	8	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	2	5.0	11	50
	pH	pH	Daily during any discharge	4	7.68	7.82	8.05	6.5-8.5
Sep-21	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	1	3.0	6	50
	pH	pH	Daily during any discharge	4	7.56	7.99	8.38	6.5-8.5
Oct-21	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	2	12.0	25	50
	pH	pH	Daily during any discharge	4	7.17	7.87	8.42	6.5-8.5
Nov-21	Oil and Grease	milligrams per litre	Daily during any discharge	7	<5	6.17	7	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	7	5	12.6	19	50
	pH	pH	Daily during any discharge	7	8.10	8.27	8.49	6.5-8.5
Dec-21	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	4	4.7	7	50
	pH	pH	Daily during any discharge	6	8.05	8.28	8.49	6.5-8.5
Jan-22	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	3	20.0	37	50
	pH	pH	Daily during any discharge	5	7.46	7.98	8.47	6.5-8.5
Feb-22	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	2	9.0	31	50
	pH	pH	Daily during any discharge	6	7.58	7.79	8.00	6.5-8.5
Mar-22	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	7	20.8	43	50
	pH	pH	Daily during any discharge	6	7.78	7.97	8.36	6.5-8.5
Apr-22	Oil and Grease	milligrams per litre	Daily during any discharge	4	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	4	3	15.3	28	50
	pH	pH	Daily during any discharge	4	7.79	8.05	8.24	6.5-8.5
May-22	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	24	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	4	7.2	14	50
	pH	pH	Daily during any discharge	5	7.36	7.98	8.35	6.5-8.5
Jun-22	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	2.7	4	50
	pH	pH	Daily during any discharge	3	7.46	7.84	8.05	6.5-8.5
Jul-22	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	0.7	3.1	10	50
	pH	pH	Daily during any discharge	6	7.13	7.71	8.30	6.5-8.5
Aug-22	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	2	5.1	14	50

	pH	pH	Daily during any discharge	5	6.65	7.46	7.96	6.5-8.5
Sep-22	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	3	4.8	6.5	50
	pH	pH	Daily during any discharge	6	6.89	7.46	7.78	6.5-8.5
Oct-22	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	2	11.4	42	50
	pH	pH	Daily during any discharge	6	7.29	7.62	8.25	6.5-8.5
Nov-22	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	2	7.3	26.3	50
	pH	pH	Daily during any discharge	6	7.44	7.88	8.23	6.5-8.5
Dec-22	Oil and Grease	milligrams per litre	Daily during any discharge	7	<5	<5	6	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	7	1	4.3	13	50
	pH	pH	Daily during any discharge	7	7.46	7.94	8.33	6.5-8.5
Jan-23	Oil and Grease	milligrams per litre	Daily during any discharge	8	<5	<6.5	13	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	8	2	5.25	16	50
	pH	pH	Daily during any discharge	8	7.24	7.96	8.48	6.5-8.5
Feb-23	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	1	7.83	18	50
	pH	pH	Daily during any discharge	6	7.39	7.80	8.08	6.5-8.5
Mar-23	Oil and Grease	milligrams per litre	Daily during any discharge	8	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	8	2	3.69	7.5	50
	pH	pH	Daily during any discharge	8	6.97	7.60	7.91	6.5-8.5
Apr-23	Oil and Grease	milligrams per litre	Daily during any discharge	7	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	7	2	5.71	10	50
	pH	pH	Daily during any discharge	7	7.59	7.77	8.20	6.5-8.5
May-23	Oil and Grease	milligrams per litre	Daily during any discharge	5	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	5	1	5.00	9	50
	pH	pH	Daily during any discharge	5	7.23	7.55	7.85	6.5-8.5
Jun-23	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	1	4.92	11	50
	pH	pH	Daily during any discharge	6	7.16	7.43	7.73	6.5-8.5
Jul-23	Oil and Grease	milligrams per litre	Daily during any discharge	7	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	7	1.8	3.26	6.5	50
	pH	pH	Daily during any discharge	7	6.58	7.41	7.99	6.5-8.5
Aug-23	Oil and Grease	milligrams per litre	Daily during any discharge	7	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	7	1.5	2.73	5	50
	pH	pH	Daily during any discharge	7	7.16	7.58	7.76	6.5-8.5
Sep-23	Oil and Grease	milligrams per litre	Daily during any discharge	7	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	7	1.1	2.53	7.8	50
	pH	pH	Daily during any discharge	7	7.12	7.70	8.08	6.5-8.5
Oct-23	Oil and Grease	milligrams per litre	Daily during any discharge	6	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	6	0.7	1.90	3	50
	pH	pH	Daily during any discharge	6	7.58	7.77	7.87	6.5-8.5
Nov-23	Oil and Grease	milligrams per litre	Daily during any discharge	3	<5	<5	<5	N/A
	Total suspended solids	milligrams per litre	Daily during any discharge	3	1	5.83	14	50
	pH	pH	Daily during any discharge	3	7.57	7.85	8.03	6.5-8.5

EPA License Number: 4458

Licensee:

SUEZ WATER PTY LIMITED

PO BOX 6059

WETHERILL PARK NSW1 2164

POINT 1

Obtained Data

Note: does not include any monitoring conducted prior to 31 March 2012.

Date Sampled	DGT Sample No.	Volume Discharged (kl)	Oil & Grease (mg/L)	Total Suspended Solids (mg/L)	pH (pH)	Date Obtained	Date Published	Notes
03-Apr-12	DGT SW1 382	4000	<5	4	8.5	26-Apr-12	5-Jul-12	
17-Apr-12	DGT SW1 383	4000	<5	2.59	8.26	26-Apr-12	5-Jul-12	
18-Apr-12	DGT SW1 384	4500	<5	9.46	7.88	31-May-12	5-Jul-12	
26-Apr-12	DGT SW1 385	4000	<5	3	8.17	31-May-12	5-Jul-12	
11-May-12	DGT SW1 386	4000	<5	5.16	7.94	31-May-12	5-Jul-12	
23-May-12	DGT SW1 387	4000	<5	2.73	8.24	31-May-12	5-Jul-12	
01-Jun-12	DGT SW1 388	3500	<5	1	7.96	13-Jun-12	5-Jul-12	
06-Jun-12	DGT SW1 389	3000	<5	7	7.39	13-Jun-12	5-Jul-12	
12-Jun-12	DGT SW1 390	4500	<5	20	7.69	20-Jun-12	5-Jul-12	
28-Jun-12	DGT SW1 391	3500	<5	1	7.93	5-Jul-12	5-Jul-12	
11-Jul-12	DGT SW1 392	3000	<5	4	7.27	2-Aug-12	2-Aug-12	
10-Aug-12	DGT SW1 393	4000	<5	2	7.97	16-Aug-12	16-Aug-12	
27-Aug-12	DGT SW1 394	4000	<5	2	7.45	3-Sep-12	3-Sep-12	
11-Sep-12	DGT SW1 395	4000	<5	7	7.55	25-Sep-12	25-Sep-12	
25-Sep-12	DGT SW1 396	3500	<5	1	7.77	3-Oct-12	8-Oct-12	
10-Oct-12	DGT SW1 397	3500	<5	2	7.66	17-Oct-12	22-Oct-12	
15-Oct-12	DGT SW1 398	3500	<5	19	7.31	22-Oct-12	22-Oct-12	
22-Oct-12	DGT SW1 399	2000	<5	19	7.31	30-Oct-12	30-Oct-12	
26-Oct-12	DGT SW1 400	2000	<5	37	6.67	31-Oct-12	31-Oct-12	
07-Nov-12	DGT SW1 401	4000	<5	4	7.79	13-Nov-12	13-Nov-12	
15-Nov-12	DGT SW1 402	2500	<5	6	7.69	23-Nov-12	23-Nov-12	
26-Nov-12	DGT SW1 403	3500	<5	3	7.79	4-Dec-12	4-Dec-12	
06-Dec-12	DGT SW1 404	3000	<5	1	7.25	13-Dec-12	13-Dec-12	
17-Dec-12	DGT SW1 405	3500	<5	1	8.48	21-Dec-12	21-Dec-12	
27-Dec-12	DGT SW1 406	4000	<5	5	8.41	9-Jan-13	9-Jan-13	
10-Jan-13	DGT SW1 407	4000	<5	1	8.17	17-Jan-13	17-Jan-13	
22-Jan-13	DGT SW1 408	3000	<5	2	8.35	30-Jan-13	30-Jan-13	
04-Feb-13	DGT SW1 409	4000	<5	5	8.5	12-Feb-13	13-Feb-13	
12-Feb-13	DGT SW1 410	3000	<5	3	8.45	19-Feb-13	19-Feb-13	
01-Mar-13	DGT SW1 411	4000	<5	22	8.45	11-Mar-13	11-Mar-13	
07-Mar-13	DGT SW1 412	2500	<5	4	8.28	13-Mar-13	13-Mar-13	
22-Mar-13	DGT SW1 413	3000	<5	1	8.35	4-Apr-13	4-Apr-13	
08-Apr-13	DGT SW1 414	4000	<5	5	8.11	15-Apr-13	15-Apr-13	
19-Apr-13	DGT SW1 415	3500	<5	3	8.36	29-Apr-13	29-Apr-13	
24-Apr-13	DGT SW1 416	3200	<5	10	7.56	2-May-13	3-May-13	
07-May-13	DGT SW1 417	3000	<5	3	7.73	15-May-13	16-May-13	
21-May-13	DGT SW1 418	3500	<5	4	7.96	30-May-13	3-Jun-13	
27-May-13	DGT SW1 419	4000	<5	8	7.64	3-Jun-13	3-Jun-13	
05-Jun-13	DGT SW1 420	3500	<5	8.5	7.67	14-Jun-13	14-Jun-13	
17-Jun-13	DGT SW1 421	3500	<5	2	8.05	25-Jun-13	26-Jun-13	
19-Jun-13	DGT SW1 422	1500	<5	1	7.90	27-Jun-13	27-Jun-13	
24-Jun-13	DGT SW1 423	3000	<5	10	8.42	1-Jul-13	2-Jul-13	
26-Jun-13	DGT SW1 424	3500	<5	5	7.89	3-Jul-13	4-Jul-13	
08-Jul-13	DGT SW1 425	3000	<5	3	8.43	16-Jul-13	16-Jul-13	
24-Jul-13	DGT SW1 426	3000	<5	1	8.17	1-Aug-13	2-Aug-13	
08-Aug-13	DGT SW1 427	3000	<5	6	8.02	15-Aug-13	15-Aug-13	
26-Aug-13	DGT SW1 428	3500	<5	4	7.64	5-Sep-13	5-Sep-13	
09-Sep-13	DGT SW1 429	3500	<5	1	7.97	17-Sep-13	18-Sep-13	
18-Sep-13	DGT SW1 430	4000	<5	5	8.45	26-Sep-13	27-Sep-13	
28-Sep-13	DGT SW1 431	3500	<5	0.5	7.81	8-Oct-13	8-Oct-13	
10-Oct-13	DGT SW1 432	3000	<5	6	7.61	21-Oct-13	21-Oct-13	
24-Oct-13	DGT SW1 433	3500	<5	5	7.76	1-Nov-13	1-Nov-13	
11-Nov-13	DGT SW1 434	3500	<5	30	8.47	19-Nov-11	20-Nov-13	
19-Nov-13	DGT SW1 435	4000	<5	38	8.43	26-Nov-13	27-Nov-13	
27-Nov-13	DGT SW1 436	2500	<5	7	7.68	4-Dec-13	4-Dec-13	
06-Dec-13	DGT SW1 437	3000	<5	10	7.63	16-Dec-13	17-Dec-13	
17-Dec-13	DGT SW1 438	2500	<5	2	8.35	9-Jan-13	9-Jan-13	
28-Dec-13	DGT SW1 439	3500	<5	3	6.81	16-Jan-14	20-Jan-14	
08-Jan-14	DGT SW1 440	3500	<5	3	8.32	16-Jan-14	20-Jan-14	
21-Jan-14	DGT SW1 441	4000	<5	2	7.96	29-Jan-14	29-Jan-14	
29-Jan-14	DGT SW1 442	4000	<5	1	8.21	5-Feb-14	6-Feb-14	
06-Feb-14	DGT SW1 443	4000	<5	1	6.95	14-Feb-14	26-Feb-14	
13-Feb-14	DGT SW1 444	3000	<5	1	8.48	25-Feb-14	26-Feb-14	
18-Feb-14	DGT SW1 445	3500	<5	7	6.71	25-Feb-14	26-Feb-14	

24-Feb-14	DGT SW1 446	4000	<5	4	7.67	3-Mar-14	3-Mar-14
28-Feb-14	DGT SW1 447	2500	<5	3	7.85	7-Mar-14	10-Mar-14
03-Mar-14	DGT SW1 448	4000	<5	6	7.93	11-Mar-14	11-Mar-14
10-Mar-14	DGT SW1 449	4500	<5	2	7.57	18-Mar-14	19-Mar-14
17-Mar-14	DGT SW1 450	4000	<5	1	7.41	1-Apr-14	15-Apr-14
24-Mar-14	DGT SW1 451	4000	<5	1	6.91	1-Apr-14	15-Apr-14
31-Mar-14	DGT SW1 452	4000	<5	5	6.64	10-Apr-14	15-Apr-14
03-Apr-14	DGT SW1 453	2000	<5	2.5	7.42	10-Apr-14	15-Apr-14
08-Apr-14	DGT SW1 454	4000	<5	1.6	6.95	16-Apr-14	16-Apr-14
11-Apr-14	DGT SW1 455	4000	<5	11	7.7	28-Apr-14	28-Apr-14
15-Apr-14	DGT SW1 456	3500	<5	5	7.06	28-Apr-14	28-Apr-14
22-Apr-14	DGT SW1 457	4500	<5	1	7.54	29-Apr-14	30-Apr-14
27-Apr-14	DGT SW1 458	4500	<5	1	8.19	6-May-14	7-May-14
02-May-14	DGT SW1 459	4500	<5	1	7.09	9-May-14	12-May-14
07-May-14	DGT SW1 460	4500	<5	1	6.57	21-May-14	26-May-14
12-May-14	DGT SW1 461	4500	<5	0.5	7.47	21-May-14	26-May-14
16-May-14	DGT SW1 462	4500	<5	1	7.57	3-Jun-14	5-Jun-14
21-May-14	DGT SW1 463	3000	<5	6	7.67	3-Jun-14	5-Jun-14
27-May-14	DGT SW1 464	2000	<5	1	7.65	3-Jun-14	5-Jun-14
02-Jun-14	DGT SW1 465	200	<5	2	7.42	20-Jun-14	20-Jun-14
03-Jun-14	DGT SW1 466	4000	<5	1	7.41	20-Jun-14	20-Jun-14
11-Jun-14	DGT SW1 467	2000	<5	3	7.69	20-Jun-14	20-Jun-14
20-Jun-14	DGT SW1 468	4000	<5	0.5	7.18	1-Jul-14	1-Jul-14
25-Jun-14	DGT SW1 469	4000	<5	0.5	7.91	3-Jul-14	7-Jul-14
30-Jun-14	DGT SW1 470	4000	<5	0.5	7.8	8-Jul-14	9-Jul-14
10-Jul-14	DGT SW1 471	3500	<5	1	8.06	23-Jul-14	24-Jul-14
18-Jul-14	DGT SW1 472	3000	<5	1	7.58	28-Jul-14	28-Jul-14
29-Jul-14	DGT SW1 473	3500	<5	1	8.37	4-Aug-14	5-Aug-14
06-Aug-14	DGT SW1 474	3500	<5	1	8.44	20-Aug-14	21-Aug-14
13-Aug-14	DGT SW1 475	4000	<5	2	8.35	20-Aug-14	21-Aug-14
18-Aug-14	DGT SW1 476	4000	<5	23	8.47	26-Aug-14	27-Aug-14
28-Aug-14	DGT SW1 477	3500	<5	8	6.62	4-Sep-14	5-Sep-14
24-Sep-14	DGT SW1 478	3000	<5	5	7.92	3-Oct-14	7-Oct-14
15-Oct-14	DGT SW1 479	4000	<5	28	6.99	29-Oct-14	30-Oct-14
11-Nov-14	DGT SW1 480	3500	<5	5	6.69	19-Nov-14	21-Nov-14
26-Nov-14	DGT SW1 481	4000	<5	3	8.12	4-Dec-14	4-Dec-14
04-Dec-14	DGT SW1 482	4000	<5	28	6.56	11-Dec-14	12-Dec-14
08-Dec-14	DGT SW1 483	4000	<5	26	7.46	16-Dec-14	16-Dec-14
18-Dec-14	DGT SW1 484	2000	<5	2	8.23	5-Jan-15	5-Jan-15
08-Jan-15	DGT SW1 485	2000	<5	0.5	8.04	19-Jan-15	20-Jan-15
12-Jan-15	DGT SW1 486	4000	<5	10	7.37	4-Feb-15	5-Feb-15
27-Jan-15	DGT SW1 487	2000	<5	3	8.09	4-Feb-15	5-Feb-15
09-Feb-15	DGT SW1 488	4000	<5	2	8.1	17-Feb-15	24-Feb-15
04-Mar-15	DGT SW1 489	4000	<5	3	8.25	11-Mar-15	12-Mar-15
20-Mar-15	DGT SW1 490	1500	<5	4	8.37	26-Mar-15	27-Mar-15
01-Apr-15	DGT SW1 491	4000	<5	4	8.42	10-Apr-15	16-Apr-15
17-Apr-15	DGT SW1 492	4000	<5	3	8.38	24-Apr-15	24-Apr-15
21-Apr-15	DGT SW1 493	4000	<5	21	8.43	1-May-15	1-May-15
22-Apr-15	DGT SW1 494	4000	<5	23	8.03	1-May-15	1-May-15
29-Apr-15	DGT SW1 495	4000	<5	13	8.39	6-May-15	7-May-15
11-May-15	DGT SW1 496	4000	<5	3	6.66	18-May-15	18-May-15
29-May-15	DGT SW1 497	3500	<5	4	7.92	4-Jun-15	5-Jun-15
17-Jun-15	DGT SW1 498	4000	<5	5	8.23	25-Jun-15	25-Jun-15
23-Jun-15	DGT SW1 499	3500	8	11	7.52	2-Jul-15	3-Jul-15
26-Jun-15	DGT SW1 500	3000	<5	1	8.34	2-Jul-15	3-Jul-15
20-Jul-15	DGT SW1 501	4000	<5	6	7.96	27-Jul-15	29-Jul-15
12-Aug-15	DGT SW1 502	4000	<5	1	8.14	20-Aug-15	21-Aug-15
25-Aug-15	DGT SW1 503	4000	<5	19	7.37	1-Sep-15	4-Sep-15
07-Sep-15	DGT SW1 504	4000	<5	3	8.47	15-Sep-15	16-Sep-15
21-Sep-15	DGT SW1 505	4000	<5	1	8.05	2-Oct-15	6-Oct-15
06-Oct-15	DGT SW1 506	4000	<5	6	7.84	14-Oct-15	14-Oct-15
19-Oct-15	DGT SW1 507	4000	<5	8	7.97	26-Oct-15	26-Oct-15
26-Oct-15	DGT SW1 508	3500	12	3	7.22	04-Nov-15	04-Nov-15
02-Nov-15	DGT SW1 509	4000	<5	2	8.45	13-Nov-15	17-Nov-15
13-Nov-15	DGT SW1 510	4000	10	26	8.42	23-Nov-15	24-Nov-15
20-Nov-15	DGT SW1 511	4000	<5	3	8.46	27-Nov-15	27-Nov-15
30-Nov-15	DGT SW1 512	4000	<5	1	8.42	18-Dec-15	31-Dec-15
10-Dec-15	DGT SW1 513	3500	<5	1	8.37	18-Dec-15	31-Dec-15
22-Dec-15	DGT SW1 514	4000	<5	5.5	7.01	14-Jan-16	15-Jan-16
04-Jan-16	DGT SW1 515	4000	<5	7	8.10	14-Jan-16	15-Jan-16
06-Jan-16	DGT SW1 516	3000	<5	10	8.25	14-Jan-16	15-Jan-16
18-Jan-16	DGT SW1 517	3500	<5	1	7.92	25-Jan-16	27-Jan-16
27-Jan-16	DGT SW1 518	3500	5	1	7.9	03-Feb-16	08-Feb-16
05-Feb-16	DGT SW1 519	3000	<5	8	7.91	12-Feb-16	15-Feb-16

22-Feb-16	DGT SW1 520	3000	72	3	8.16	08-Mar-16	10-Mar-16	Sample Potentially Contaminated.No visible Oil&Grease during discharge. Not consistant with past and present results
13-Mar-16	DGT SW1 521	3500	<5	1	8.04	23-Mar-16	14-Apr-16	
06-Apr-16	DGT SW1 522	3500	<5	1	8.12	12-Apr-16	14-Apr-16	
21-Apr-16	DGT SW1 523	3500	<5	1	8.01	13-May-16	16-May-16	
06-May-16	DGT SW1 524	3000	<5	1	7.23	13-May-16	16-May-16	
24-May-16	DGT SW1 525	3500	<5	1	7.89	16-Jun-16	17-Jun-16	
05-Jun-16	DGT SW1 526	4000	27	27	7.09	16-Jun-16	17-Jun-16	Thunderstorms in Sydney, emergency discharges to prevent flooding. Not representative Sample
05-Jun-16	DGT SW1 527	2800	<5	27	7.56	16-Jun-16	17-Jun-16	
17-Jun-16	DGT SW1 528	3500	<5	6	7.88	06-Jul-16	13-Jul-16	
29-Jun-16	DGT SW1 529	4000	<5	1	8.17	06-Jul-16	13-Jul-16	
15-Jul-16	DGT SW1 530	4000	<5	7	8.17	29-Jul-16	03-Aug-16	
26-Jul-16	DGT SW1 531	4000	<5	2	7.9	29-Jul-16	03-Aug-16	
12-Aug-16	DGT SW1 532	4000	<5	3	8.35	22-Aug-16	24-Aug-16	
25-Aug-16	DGT SW1 533	4000	<5	1	8.35	01-Sep-16	09-Sep-16	
14-Sep-16	DGT SW1 534	4000	<5	6	8.23	21-Sep-16	23-Sep-16	
13-Oct-16	DGT SW1 535	4000	<5	2	8.37	21-Oct-16	31-Oct-16	
02-Nov-16	DGT SW1 536	4000	<5	8	8.29	09-Nov-16	10-Nov-16	
21-Nov-16	DGT SW1 537	3500	<5	1	8.25	28-Nov-16	29-Nov-16	
05-Dec-16	DGT SW1 538	3500	<5	2	8.22	14-Dec-16	05-Jan-17	
16-Dec-16	DGT SW1 539	4000	<5	6	8.17	16-Jan-17	17-Jan-17	
29-Dec-16	DGT SW1 540	2400	<5	4	7.46	20-Jan-17	23-Jan-17	
10-Jan-17	DGT SW1 541	2500	<5	1	8.36	20-Jan-17	20-Jan-17	
30-Jan-17	DGT SW1 542	4000	<5	3	8.35	13-Feb-17	13-Feb-17	
14-Feb-17	DGT SW1 543	4000	<5	1	8.35	24-Feb-17	24-Feb-17	
27-Feb-17	DGT SW1 544	4000	<5	17	7.76	08-Mar-17	09-Mar-17	
02-Mar-17	DGT SW1 545	3500	<5	38	8.29	08-Mar-17	09-Mar-17	
14-Mar-17	DGT SW1 546	3500	<5	8	7.87	20-Mar-17	21-Mar-17	
18-Mar-17	DGT SW1 547	3000	<5	36.3	8.11	27-Mar-17	27-Mar-17	
29-Mar-17	DGT SW1 548	4000	<5	1	7.78	06-Apr-17	06-Apr-17	
04-Apr-17	DGT SW1 549	4000	<5	12	7.42	11-Apr-17	11-Apr-17	
20-Apr-17	DGT SW1 550	3500	<5	1	7.75	01-May-17	01-May-17	
09-May-17	DGT SW1 551	3500	<5	1	8.21	16-May-17	31-May-17	
23-May-17	DGT SW1 552	4000	<5	2	7.48	08-Jun-17	15-Jun-17	
07-Jun-17	DGT SW1 553	4000	<5	7	7.77	22-Jun-17	23-Jun-17	
15-Jun-17	DGT SW1 554	3500	<5	5	8.35	22-Jun-17	23-Jun-17	
06-Jul-17	DGT SW1 555	4000	<5	2	8.49	14-Jul-17	18-Jul-17	
20-Jul-17	DGT SW1 556	3500	<5	4	8.17	26-Jul-17	27-Jul-17	
02-Aug-17	DGT SW1 557	3500	<5	1.5	8.09	09-Aug-17	10-Aug-17	
16-Aug-17	DGT SW1 558	4000	<5	2	8.29	21-Aug-17	21-Aug-17	
31-Aug-17	DGT SW1 559	3500	<5	1	8.27	06-Sep-17	06-Sep-17	
20-Sep-17	DGT SW1 560	4000	<5	2	8.47	27-Sep-17	03-Oct-17	
06-Oct-17	DGT SW1 561	3500	<5	5.5	8.44	13-Sep-17	13-Oct-17	
20-Oct-17	DGT SW1 562	4000	<5	2.5	7.70	27-Oct-17	30-Oct-17	
02-Nov-17	DGT SW1 563	2500	<5	1	8.11	08-Nov-17	08-Nov-17	
16-Nov-17	DGT SW1 564	2700	<5	1	8.16	23-Nov-17	28-Nov-17	
01-Dec-17	DGT SW1 565	2500	<5	1	8.26	11-Dec-17	11-Dec-17	
12-Dec-17	DGT SW1 566	2700	<5	1	8.23	21-Dec-17	21-Dec-17	
22-Dec-17	DGT SW1 567	2500	<5	1	7.76	09-Jan-18	09-Jan-18	
05-Jan-18	DGT SW1 568	2700	<5	1	7.95	15-Jan-18	15-Jan-18	
16-Jan-18	DGT SW1 569	2500	<5	2.5	8.16	24-Jan-18	24-Jan-18	
31-Jan-18	DGT SW1 570	2500	<5	1	7.89	07-Feb-18	7-Feb-18	
13-Feb-18	DGT SW1 571	2500	<5	1	8.16	22-Feb-18	22-Feb-18	
26-Feb-18	DGT SW1 572	2700	<5	6.5	7.56	06-Mar-18	06-Mar-18	
07-Mar-18	DGT SW1 573	2700	<5	2.5	8.13	19-Mar-18	19-Mar-18	
12-Mar-18	DGT SW1 574	2700	<5	1	8.29	19-Mar-18	19-Mar-18	
21-Mar-18	DGT SW1 575	2700	<5	4	7.33	03-Apr-18	09-Apr-18	
28-Mar-18	DGT SW1 576	2700	<5	2	7.9	11-Apr-18	11-Apr-18	
06-Apr-18	DGT SW1 577	2700	<5	2	8.39	17-Apr-18	24-Apr-18	
16-Apr-18	DGT SW1 578	2700	<5	1.5	8.18	24-Apr-18	24-Apr-18	
24-Apr-18	DGT SW1 579	2700	<5	1.2	8.46	03-May-18	03-May-18	
30-Apr-18	DGT SW1 580	2700	<5	4	8.03	08-May-18	16-May-18	
08-May-18	DGT SW1 581	2700	<5	1.5	8.27	16-May-18	16-May-18	
21-May-18	DGT SW1 582	2700	<5	1	8.02	01-Jun-18	04-Jun-18	
30-May-18	DGT SW1 583	2700	<5	3	8.43	08-Jun-18	13-Jun-18	
06-Jun-18	DGT SW1 584	4000	<5	5	8.02	14-Jun-18	14-Jun-18	
11-Jun-18	DGT SW1 585	4000	<5	0.56	8.35	19-Jun-18	19-Jun-18	
20-Jun-18	DGT SW1 586	4000	<5	7.8	8.00	29-Jun-18	02-Jul-18	
26-Jun-18	DGT SW1 587	3000	<5	2	8.34	03-Jul-18	05-Jul-18	
09-Jul-18	DGT SW1 588	2700	<5	1	8.48	18-Jul-18	18-Jul-18	
27-Jul-18	DGT SW1 589	3000	<5	2	7.66	03-Aug-18	06-Aug-18	
07-Aug-18	DGT SW1 590	2700	<5	1	7.96	14-Aug-18	14-Aug-18	

17-Aug-18	DGT SW1 591	4000	<5	5	8	24-Aug-18	24-Aug-18	
20-Aug-18	DGT SW1 592	3000	<5	1	8.18	31-Aug-18	03-Sep-18	
29-Aug-18	DGT SW1 593	3000	<5	1	7.66	05-Sep-18	06-Sep-18	
06-Sep-18	DGT SW1 594	2700	<5	2	8.06	20-Sep-18	21-Sep-18	
18-Sep-18	DGT SW1 595	4000	<5	1	7.97	26-Sep-18	05-Oct-18	
28-Sep-18	DGT SW1 596	3000	<5	4	7.94	09-Oct-18	12-Oct-18	
05-Oct-18	DGT SW1 597	3000	11	44	8.37	12-Oct-18	15-Oct-18	Heavy rainfall overnight and storm water run-off. No visible Oil&Grease during discharge.
12-Oct-18	DGT SW1 598	3000	<5	3.5	7.56	18-Oct-18	22-Oct-18	
15-Oct-18	DGT SW1 599	3000	<5	13	7.85	22-Oct-18	24-Oct-18	
18-Oct-18	DGT SW1 600	3000	<5	5.5	8.38	26-Oct-18	29-Oct-18	
22-Oct-18	DGT SW1 601	4000	<5	1	8.28	30-Oct-18	07-Nov-18	
25-Oct-18	DGT SW1 602	1000	<5	1	8.25	02-Nov-18	07-Nov-18	
26-Oct-18	DGT SW1 603	100	<5	5.5	8.43	02-Nov-18	07-Nov-18	
29-Oct-18	DGT SW1 604	100	<5	2	8.47	06-Nov-18	13-Nov-18	
30-Oct-18	DGT SW1 605	20	<5	7	7.36	06-Nov-18	13-Nov-18	
31-Oct-18	DGT SW1 606	20	<5	2	8.42	09-Nov-18	13-Nov-18	
01-Nov-18	DGT SW1 607	20	<5	2	8.47	09-Nov-18	13-Nov-18	
12-Nov-18	DGT SW1 608	2700	<5	8	7.77	21-Nov-18	28-Nov-18	
27-Nov-18	DGT SW1 609	2000	<5	2	8.33	06-Dec-18	13-Dec-18	
30-Nov-18	DGT SW1 610	2700	<5	5	8.11	07-Dec-18	13-Dec-18	
14-Dec-18	DGT SW1 611	3000	<5	20	6.83	28-Dec-19	05-Jan-19	
18-Dec-18	DGT SW1 612	2000	<5	8	8.34	28-Dec-19	05-Jan-19	
24-Dec-18	DGT SW1 613	2700	<5	5	8.4	04-Jan-19	05-Jan-19	
03-Jan-19	DGT SW1 614	2000	<5	1	8.12	11-Jan-19	23-Jan-19	
11-Jan-19	DGT SW1 615	2700	<5	2	7.14	22-Jan-19	23-Jan-19	
21-Jan-19	DGT SW1 616	2700	<5	16	8.43	30-Jan-19	04-Feb-19	
30-Jan-19	DGT SW1 617	2700	<5	2.5	8.15	07-Feb-19	15-Feb-19	
08-Feb-19	DGT SW1 618	2500	<5	2	8.47	14-Feb-19	25-Feb-19	
13-Feb-19	DGT SW1 619	2700	<5	4	8.41	19-Feb-19	25-Feb-19	
22-Feb-19	DGT SW1 620	2700	<5	1	8.02	01-Mar-19	08-Mar-19	
05-Mar-19	DGT SW1 621	2700	<5	1	8.32	12-Mar-19	25-Mar-19	
15-Mar-19	DGT SW1 622	3000	<5	23	8.28	21-Mar-19	25-Mar-19	
18-Mar-19	DGT SW1 623	4000	<5	19	8.01	26-Mar-19	29-Mar-19	
25-Mar-19	DGT SW1 624	2700	<5	14	7.86	30-Mar-19	16-Apr-19	
02-Apr-19	DGT SW1 625	2700	<5	2	7.92	08-Apr-19	16-Apr-19	
10-Apr-19	DGT SW1 626	2000	<5	4	8.46	16-Apr-19	30-Apr-19	
23-Apr-19	DGT SW1 627	2500	<5	1	7.91	30-Apr-19	03-Apr-19	
08-May-19	DGT SW1 628	2500	<5	1	8.12	14-May-19	27-May-19	
20-May-19	DGT SW1 629	2700	<5	1	8.08	05-Jun-19	19-Jun-19	
30-May-19	DGT SW1 630	2500	<5	3	6.99	06-Jun-19	19-Jun-19	
07-Jun-19	DGT SW1 631	2700	<5	7	8.01	17-Jun-19	19-Jun-19	
14-Jun-19	DGT SW1 632	2700	<5	3	8.38	21-Jun-19	01-Jul-19	
24-Jun-19	DGT SW1 633	2700	<5	5	8.11	28-Jun-19	01-Jul-19	
04-Jul-19	DGT SW1 634	2700	<5	5	8.28	11-Jul-19	15-Jul-19	
12-Jul-19	DGT SW1 635	2700	<5	2.5	8.18	29-Jul-19	01-Aug-19	
29-Jul-19	DGT SW1 636	2700	<5	2	7.85	06-Aug-19	20-Jul-19	
12-Aug-19	DGT SW1 637	2700	<5	1	7.94	19-Aug-19	20-Aug-19	
20-Aug-19	DGT SW1 638	2700	<5	1	8.19	30-Aug-19	11-Sep-19	
28-Aug-19	DGT SW1 639	2700	<5	5	7.57	10-Sep-19	11-Sep-19	
03-Sep-19	DGT SW1 640	2700	<5	4	7.68	10-Sep-19	11-Sep-19	
17-Sep-19	DGT SW1 641	3000	<5	7	7.14	26-Sep-19	03-Oct-19	
19-Sep-19	DGT SW1 642	2700	<5	18	8.47	26-Sep-19	03-Oct-19	
02-Oct-19	DGT SW1 643	2700	<5	3	8.25	09-Oct-19	14-Oct-19	
18-Oct-19	DGT SW1 644	2700	<5	15	7.56	28-Oct-19	11-Nov-19	
08-Nov-19	DGT SW1 645	2700	<5	3	8.45	15-Nov-19	29-Nov-19	
03-Dec-19	DGT SW1 646	2700	<5	1	8.1	11-Dec-19	19-Dec-19	
20-Dec-19	DGT SW1 647	2700	<5	1	7.03	03-Jan-20	14-Jan-20	
03-Jan-20	DGT SW1 648	2700	<5	1	8.34	08-Jan-20	14-Jan-20	
16-Jan-20	DGT SW1 649	2700	<5	4	6.9	23-Jan-20	03-Feb-20	
31-Jan-20	DGT SW1 650	2700	<5	1	8.3	07-Feb-20	11-Feb-20	
05-Feb-20	DGT SW1 651	2700	<5	8	7.92	14-Feb-20	19-Feb-20	
07-Feb-20	DGT SW1 652	2700	<5	22	7.65	17-Feb-20	19-Feb-20	
08-Feb-20	DGT SW1 653	2700	<5	33	7.44	17-Feb-20	19-Feb-20	
09-Feb-20	DGT SW1 654	2700	<5	35	7.95	17-Feb-20	19-Feb-20	
16-Feb-20	DGT SW1 655	2700	<5	10	8.08	25-Feb-20	28-Feb-20	
25-Feb-20	DGT SW1 656	2700	<5	2	8.32	16-Mar-20	17-Mar-20	
08-Mar-20	DGT SW1 657	2700	<5	3	8.2	16-Mar-20	17-Mar-20	
20-Mar-20	DGT SW1 658	2700	7	2	8.32	31-Mar-20	07-Apr-20	
31-Mar-20	DGT SW1 659	2700	<5	2	7.23	06-Apr-20	07-Apr-20	
08-Apr-20	DGT SW1 660	2700	<5	1	7.62	17-Apr-20	21-Apr-20	
21-Apr-20	DGT SW1 661	2700	<5	1	7.68	28-Apr-20	08-May-20	
01-May-20	DGT SW1 662	2700	<5	15.9	6.68	08-May-20	08-May-20	
18-May-20	DGT SW1 663	2700	<5	3.5	7.31	26-May-20	01-Jun-20	
01-Jun-20	DGT SW1 664	2700	<5	3.5	7.37	15-Jun-20	15-Jun-20	

16-Jun-20	DGT SW1 665	3000	<5	1	8.11	22-Jun-20	30-Jun-20	
29-Jun-20	DGT SW1 666	2700	<5	2	7.68	03-Jul-20	15-Jul-20	
14-Jul-20	DGT SW1 667	2700	<5	6	7.69	21-Jul-20	03-Aug-20	
26-Jul-20	DGT SW1 668	2700	<5	18	8.28	03-Aug-20	10-Aug-20	
30-Jul-20	DGT SW1 669	2700	6	4	7.66	07-Aug-20	10-Aug-20	
08-Aug-20	DGT SW1 670	2700	<5	6	7.23	17-Aug-20	24-Aug-20	
10-Aug-20	DGT SW1 671	2700	<5	24	7.98	17-Aug-20	24-Aug-20	
24-Aug-20	DGT SW1 672	2700	<5	4	8.41	28-Aug-20	07-Sep-20	
06-Sep-20	DGT SW1 673	2700	<5	6	8.41	15-Sep-20	25-Sep-20	
21-Sep-20	DGT SW1 674	2700	<5	9	8.37	30-Sep-20	30-Sep-20	
06-Oct-20	DGT SW1 675	2700	<5	3	7.9	14-Oct-20	16-Oct-20	
19-Oct-20	DGT SW1 676	2700	<5	2	7.44	27-Oct-11	03-Nov-20	
25-Oct-20	DGT SW1 677	3000	<5	5	8.47	30-Oct-11	03-Nov-20	
31-Oct-20	DGT SW1 678	2600	<5	6	8.33	19-Nov-20	30-Nov-20	
12-Nov-20	DGT SW1 679	2500	<5	1	8.22	19-Nov-20	30-Nov-20	
19-Nov-20	DGT SW1 680	2700	<5	1	8.24	27-Nov-20	30-Nov-20	
27-Nov-20	DGT SW1 681	2500	<5	3	7.97	04-Dec-20	14-Dec-20	
02-Dec-20	DGT SW1 682	2500	<5	13	7.97	10-Dec-20	14-Dec-20	
12-Dec-20	DGT SW1 683	2500	<5	2	8.22	21-Dec-20	04-Jan-21	
17-Dec-20	DGT SW1 684	2500	<5	6	8.19	30-Dec-20	04-Jan-21	
22-Dec-20	DGT SW1 685	2500	<5	14	7.55	13-Jan-21	14-Jan-21	
29-Dec-20	DGT SW1 686	2500	<5	31	7.87	13-Jan-21	14-Jan-21	
06-Jan-21	DGT SW1 687	2500	<5	7	8.03	13-Jan-21	14-Jan-21	
15-Jan-21	DGT SW1 688	2700	<5	3	7.38	28-Jan-21	10-Feb-21	
27-Jan-21	DGT SW1 689	2700	<5	1	7.95	02-Feb-21	10-Feb-21	
31-Jan-21	DGT SW1 690	2700	<5	3	7.86	05-Feb-21	10-Feb-21	
02-Feb-21	DGT SW1 691	2700	<5	17	7.48	10-Feb-21	10-Feb-21	
11-Feb-21	DGT SW1 692	2700	<5	2	8.37	22-Feb-21	26-Feb-21	
18-Feb-21	DGT SW1 693	1500	6	5	8.21	25-Feb-21	26-Feb-21	
01-Mar-21	DGT SW1 694	2700	<5	4	7.68	09-Mar-21	18-Mar-21	
09-Mar-21	DGT SW1 695	2700	<5	10	7.18	17-Mar-21	18-Mar-21	
15-Mar-21	DGT SW1 696	2700	11	11	7.26	26-Mar-21	30-Mar-21	No visible Oil&Grease during discharge.
18-Mar-21	DGT SW1 697	2700	9	22	7.4	26-Mar-21	30-Mar-21	
23-Mar-21	DGT SW1 698	3000	<5	15	7.95	01-Apr-21	09-Apr-21	
01-Apr-21	DGT SW1 699	2700	<5	3	7.85	16-Apr-21	30-Apr-21	
13-Apr-21	DGT SW1 700	2700	<5	1	8.08	23-Apr-21	30-Apr-21	
29-Apr-21	DGT SW1 701	2700	<5	1	7.36	18-May-21	26-May-21	
08-May-21	DGT SW1 702	2700	<5	5	7.56	18-May-21	26-May-21	
24-May-21	DGT SW1 703	2700	<5	1	7.7	02-Jun-21	08-Jun-21	
04-Jun-21	DGT SW1 704	2700	<5	4	6.9	15-Jun-21	28-Jun-21	
13-Jun-21	DGT SW1 705	2700	<5	5	8.33	29-Jun-21	02-Jul-21	
23-Jun-21	DGT SW1 706	2000	<5	2	7.89	02-Jul-21	02-Jul-21	
30-Jun-21	DGT SW1 707	2000	6	6	7.67	08-Jul-21	14-Jul-21	
08-Jul-21	DGT SW1 708	2000	<5	2	7.6	16-Jul-21	30-Jul-21	
18-Jul-21	DGT SW1 709	2000	5	1	8.11	23-Jul-21	05-Aug-21	
26-Jul-21	DGT SW1 710	2700	<5	4	7.4	04-Aug-21	05-Aug-21	
01-Aug-21	DGT SW1 711	2700	<5	4	7.78	06-Aug-21	20-Aug-21	
09-Aug-21	DGT SW1 712	2300	<5	3	7.76	24-Aug-21	30-Aug-21	
18-Aug-21	DGT SW1 713	2700	8	2	8.05	27-Aug-21	30-Aug-21	
24-Aug-21	DGT SW1 714	2700	<5	11	7.68	01-Sep-21	13-Sep-21	
01-Sep-21	DGT SW1 715	2700	<5	1	8.38	10-Sep-21	20-Sep-21	
06-Sep-21	DGT SW1 716	2700	<5	3	7.92	13-Sep-21	20-Sep-21	
15-Sep-21	DGT SW1 717	2700	<5	6	7.56	24-Sep-21	08-Oct-21	
24-Sep-21	DGT SW1 718	2700	<5	2	8.09	06-Oct-21	08-Oct-21	
05-Oct-21	DGT SW1 719	2700	<5	7	7.66	14-Oct-21	19-Oct-21	
12-Oct-21	DGT SW1 720	2700	<5	2	8.42	18-Oct-21	19-Oct-21	
17-Oct-21	DGT SW1 721	2700	<5	14	8.24	26-Oct-21	05-Nov-21	
23-Oct-21	DGT SW1 722	2700	<5	25	7.17	04-Nov-21	05-Nov-21	
01-Nov-21	DGT SW1 723	2700	7	8	8.1	11-Nov-21	23-Nov-21	
05-Nov-21	DGT SW1 724	2700	<5	18	8.19	12-Nov-21	23-Nov-21	
07-Nov-21	DGT SW1 725	1000	<5	15	8.1	16-Nov-21	23-Nov-21	
12-Nov-21	DGT SW1 726	3000	<5	19	8.25	18-Nov-21	23-Nov-21	
19-Nov-21	DGT SW1 727	2700	<5	5	8.31	29-Nov-21	10-Dec-21	
23-Nov-21	DGT SW1 728	2700	<5	5	8.49	03-Dec-21	10-Dec-21	
26-Nov-21	DGT SW1 729	2700	<5	18	8.45	03-Dec-21	10-Dec-21	
02-Dec-21	DGT SW1 730	2700	<5	4	8.27	10-Dec-21	10-Dec-21	
08-Dec-21	DGT SW1 731	2700	<5	4	8.49	20-Dec-21	05-Jan-22	
11-Dec-21	DGT SW1 732	3000	<5	5	8.05	22-Dec-21	05-Jan-22	
17-Dec-21	DGT SW1 733	2700	<5	4	8.48	05-Jan-22	05-Jan-22	
23-Dec-21	DGT SW1 734	2700	<5	7	8.3	07-Jan-22	19-Jan-22	
29-Dec-21	DGT SW1 735	2700	<5	4	8.09	07-Jan-22	19-Jan-22	
06-Jan-22	DGT SW1 736	3000	<5	35	8.3	13-Jan-22	19-Jan-22	
08-Jan-22	DGT SW1 737	2700	<5	22	8.11	14-Jan-22	19-Jan-22	
13-Jan-22	DGT SW1 738	3000	<5	37	8.47	24-Jan-22	07-Feb-22	
18-Jan-22	DGT SW1 739	2700	<5	3	7.54	25-Jan-22	07-Feb-22	

24-Jan-22	DGT SW1 740	2700	<5	3	7.46	01-Feb-22	07-Feb-22	
01-Feb-22	DGT SW1 741	2700	<5	2	8	11-Feb-22	22-Feb-22	
05-Feb-22	DGT SW1 742	2700	<5	3	7.8	11-Feb-22	22-Feb-22	
12-Feb-22	DGT SW1 743	2700	<5	5	8	24-Feb-22	08-Mar-22	
19-Feb-22	DGT SW1 744	2700	<5	6	7.73	01-Mar-22	08-Mar-22	
23-Feb-22	DGT SW1 745	4000	<5	31	7.58	03-Mar-22	08-Mar-22	
25-Feb-22	DGT SW1 746	2700	<5	7	7.6	04-Mar-22	08-Mar-22	
01-Mar-22	DGT SW1 747	3000	<5	43	7.78	10-Mar-22	23-Mar-22	
02-Mar-22	DGT SW1 748	3000	<5	28	7.91	10-Mar-22	23-Mar-22	
07-Mar-22	DGT SW1 749	3000	<5	25	7.87	30-Mar-22	05-Apr-22	
19-Mar-22	DGT SW1 750	3000	<5	7	8.01	30-Mar-22	05-Apr-22	
26-Mar-22	DGT SW1 751	2700	<5	13	7.89	06-Apr-22	14-Apr-22	
29-Mar-22	DGT SW1 752	2700	<5	9	8.36	06-Apr-22	14-Apr-22	
01-Apr-22	DGT SW1 753	2700	<5	20	7.79	12-Apr-22	14-Apr-22	
05-Apr-22	DGT SW1 754	2700	<5	3	8.24	13-Apr-22	14-Apr-22	
08-Apr-22	DGT SW1 755	3000	<5	28	8.16	02-May-22	12-May-22	
22-Apr-22	DGT SW1 756	2700	<5	10	7.99	02-May-22	12-May-22	
05-May-22	DGT SW1 757	2700	<5	4	8.22	17-May-22	31-May-22	
11-May-22	DGT SW1 758	2700	<5	14	8.35	20-May-22	31-May-22	
15-May-22	DGT SW1 759	2700	<5	7	7.76	20-May-22	31-May-22	
22-May-22	DGT SW1 760	2700	<5	7	7.36	07-Jun-22	15-Jun-22	
28-May-22	DGT SW1 761	2700	24	4	8.21	14-Jun-22	15-Jun-22	No visible oil and grease during discharge (recorded by sampler). Result is not consistent with past and present results. Sample potentially contaminated during analysis.
05-Jun-22	DGT SW1 762	2700	<5	4	8	17-Jun-22	01-Jul-22	
13-Jun-22	DGT SW1 763	2700	<5	3	7.46	22-Jun-22	01-Jul-22	
24-Jun-22	DGT SW1 764	2700	<5	1	8.05	04-Jul-22	15-Jul-22	
01-Jul-22	DGT SW1 765	2500	<5	2	7.63	11-Jul-22	15-Jul-22	
04-Jul-22	DGT SW1 766	4000	<5	0.9	7.94	11-Jul-22	15-Jul-22	
08-Jul-22	DGT SW1 767	2700	<5	2	8.3	15-Jul-22	27-Jul-22	
13-Jul-22	DGT SW1 768	2700	<5	10	7.53	20-Jul-22	27-Jul-22	
19-Jul-22	DGT SW1 769	2700	<5	0.7	7.71	27-Jul-22	27-Jul-22	
25-Jul-22	DGT SW1 770	2700	<5	2.8	7.13	02-Aug-22	08-Aug-22	
01-Aug-22	DGT SW1 771	2700	<5	3.6	7.96	09-Aug-22	17-Aug-22	
10-Aug-22	DGT SW1 772	4000	<5	14	7.77	17-Aug-22	17-Aug-22	
17-Aug-22	DGT SW1 773	2700	<5	2	7.62	24-Aug-22	31-Aug-22	
23-Aug-22	DGT SW1 774	2700	<5	3	7.31	31-Aug-22	31-Aug-22	
30-Aug-22	DGT SW1 775	2700	<5	3	6.65	12-Sep-22	23-Sep-22	
04-Sep-22	DGT SW1 776	2700	<5	3	7.57	12-Sep-22	23-Sep-22	
07-Sep-22	DGT SW1 777	1500	<5	6.5	7.51	16-Sep-22	23-Sep-22	
16-Sep-22	DGT SW1 778	2700	<5	6.5	7.78	26-Sep-22	6-Oct-22	
22-Sep-22	DGT SW1 779	2700	<5	4	6.89	29-Sep-22	6-Oct-22	
27-Sep-22	DGT SW1 780	2700	<5	4.6	7.65	4-Oct-22	6-Oct-22	
30-Sep-22	DGT SW1 781	1500	<5	4	7.37	12-Oct-22	24-Oct-22	
05-Oct-22	DGT SW1 782	2700	<5	8	7.44	12-Oct-22	24-Oct-22	
08-Oct-22	DGT SW1 783	2700	<5	42	8.25	17-Oct-22	24-Oct-22	
15-Oct-22	DGT SW1 784	2700	<5	3.5	7.75	24-Oct-22	24-Oct-22	
22-Oct-22	DGT SW1 785	2700	<5	4	7.29	31-Oct-22	10-Nov-22	
25-Oct-22	DGT SW1 786	2700	<5	9	7.41	2-Nov-22	10-Nov-22	
30-Oct-22	DGT SW1 787	2700	<5	2	7.6	4-Nov-22	10-Nov-22	
04-Nov-22	DGT SW1 788	2700	<5	3	8.03	11-Nov-22	24-Nov-22	
11-Nov-22	DGT SW1 789	2700	<5	2	7.78	21-Nov-22	24-Nov-22	
14-Nov-22	DGT SW1 790	2700	<5	26.3	8.23	24-Nov-22	24-Nov-22	
19-Nov-22	DGT SW1 791	2700	<5	2	7.44	28-Nov-22	9-Dec-22	
24-Nov-22	DGT SW1 792	2700	<5	5.49	8	1-Dec-22	9-Dec-22	
30-Nov-22	DGT SW1 793	2700	<5	5	7.8	9-Dec-22	20-Dec-22	
05-Dec-22	DGT SW1 794	2700	<5	2.5	8.32	9-Dec-22	20-Dec-22	
08-Dec-22	DGT SW1 795	2700	<5	6.5	8.08	15-Dec-22	20-Dec-22	
13-Dec-22	DGT SW1 796	2700	<5	13	7.58	20-Dec-22	20-Dec-22	
18-Dec-22	DGT SW1 797	2700	<5	2.2	7.96	3-Jan-23	12-Jan-23	
19-Dec-22	DGT SW1 798	2700	<5	2	8.33	3-Jan-23	12-Jan-23	
24-Dec-22	DGT SW1 799	2700	<5	1	7.88	10-Jan-23	12-Jan-23	
30-Dec-22	DGT SW1 800	2700	6	3	7.46	11-Jan-23	12-Jan-23	
04-Jan-23	DGT SW1 801	2700	13	3	7.24	12-Jan-23	12-Jan-23	No oils or grease visible during discharge, as recorded by sampler. Rainfall event
07-Jan-23	DGT SW1 802	2700	<5	9	8.4	17-Jan-23	31-Jan-23	
12-Jan-23	DGT SW1 803	2700	<5	2	8.19	19-Jan-23	31-Jan-23	
16-Jan-23	DGT SW1 804	2700	<5	2	8.48	20-Jan-23	31-Jan-23	
19-Jan-23	DGT SW1 805	2700	<5	4	8.28	30-Jan-23	31-Jan-23	
23-Jan-23	DGT SW1 806	2700	<5	4	7.62	31-Jan-23	31-Jan-23	
24-Jan-23	DGT SW1 807	2700	<5	2	7.85	6-Feb-23	10-Feb-23	
31-Jan-23	DGT SW1 808	2700	<5	16	7.61	7-Feb-23	10-Feb-23	
06-Feb-23	DGT SW1 809	2700	<5	1	7.77	14-Feb-23	27-Feb-23	
09-Feb-23	DGT SW1 810	2700	<5	18	7.93	15-Feb-23	27-Feb-23	

14-Feb-23	DGT SW1 811	2700	<5	3	7.89	21-Feb-23	27-Feb-23
19-Feb-23	DGT SW1 812	2700	<5	5	7.39	24-Feb-23	27-Feb-23
22-Feb-23	DGT SW1 813	2700	<5	14	7.72	28-Feb-23	13-Mar-23
26-Feb-23	DGT SW1 814	2700	<5	6	8.08	3-Mar-23	13-Mar-23
02-Mar-23	DGT SW1 815	2700	<5	3	6.97	9-Mar-23	13-Mar-23
05-Mar-23	DGT SW1 816	2700	<5	2	7.68	13-Mar-23	13-Mar-23
10-Mar-23	DGT SW1 817	2700	<5	7.5	7.54	21-Mar-23	24-Mar-23
15-Mar-23	DGT SW1 818	2700	<5	2	7.76	22-Mar-23	24-Mar-23
18-Mar-23	DGT SW1 819	2700	<5	7	7.84	24-Mar-23	24-Mar-23
22-Mar-23	DGT SW1 820	2700	<5	2	7.73	27-Mar-23	6-Apr-23
25-Mar-23	DGT SW1 821	2700	<5	2	7.91	5-Apr-23	6-Apr-23
31-Mar-23	DGT SW1 822	3000	<5	4	7.33	5-Apr-23	6-Apr-23
05-Apr-23	DGT SW1 823	2700	<5	6	7.59	18-Apr-23	28-Apr-23
10-Apr-23	DGT SW1 824	2700	<5	2	7.72	18-Apr-23	28-Apr-23
12-Apr-23	DGT SW1 825	3000	<5	4	7.82	20-Apr-23	28-Apr-23
18-Apr-23	DGT SW1 826	3000	<5	10	7.67	26-Apr-23	28-Apr-23
21-Apr-23	DGT SW1 827	2700	<5	3	7.65	1-May-23	12-May-23
27-Apr-23	DGT SW1 828	2700	<5	5	7.76	4-May-23	12-May-23
30-Apr-23	DGT SW1 829	2700	<5	10	8.2	8-May-23	12-May-23
05-May-23	DGT SW1 830	2700	<5	9	7.49	12-May-23	12-May-23
10-May-23	DGT SW1 831	2700	<5	8	7.53	18-May-23	31-May-23
15-May-23	DGT SW1 832	2700	<5	4	7.64	23-May-23	31-May-23
19-May-23	DGT SW1 833	2700	<5	3	7.23	26-May-23	31-May-23
26-May-23	DGT SW1 834	2700	<5	1	7.85	2-Jun-23	16-Jun-23
01-Jun-23	DGT SW1 835	2700	<5	3	7.49	8-Jun-23	16-Jun-23
08-Jun-23	DGT SW1 836	2700	<5	11	7.73	15-Jun-23	29-Jun-23
12-Jun-23	DGT SW1 837	2700	<5	1	7.67	22-Jun-23	29-Jun-23
16-Jun-23	DGT SW1 838	2700	<5	5	7.36	23-Jun-23	29-Jun-23
22-Jun-23	DGT SW1 839	2700	<5	6	7.16	28-Jun-23	29-Jun-23
27-Jun-23	DGT SW1 840	2700	<5	3.5	7.19	3-Jul-23	17-Jul-23
02-Jul-23	DGT SW1 841	2700	<5	2	7.48	7-Jul-23	17-Jul-23
07-Jul-23	DGT SW1 842	2700	<5	6.5	6.58	18-Jul-23	2-Aug-23
13-Jul-23	DGT SW1 843	3000	<5	4	7.59	20-Jul-23	2-Aug-23
18-Jul-23	DGT SW1 844	2700	<5	3.5	6.7	25-Jul-23	2-Aug-23
22-Jul-23	DGT SW1 845	2700	<5	1.8	7.67	2-Jul-23	2-Aug-23
27-Jul-23	DGT SW1 846	2700	<5	2	7.83	3-Aug-23	14-Aug-23
31-Jul-23	DGT SW1 847	2700	<5	3	7.99	7-Aug-23	14-Aug-23
04-Aug-23	DGT SW1 848	2700	<5	1.5	7.43	10-Aug-23	14-Aug-23
08-Aug-23	DGT SW1 849	2700	<5	5	7.16	14-Aug-23	28-Aug-23
11-Aug-23	DGT SW1 850	1500	<5	2	7.71	17-Aug-23	28-Aug-23
15-Aug-23	DGT SW1 851	2700	<5	4.3	7.68	28-Aug-23	28-Aug-23
21-Aug-23	DGT SW1 852	2700	<5	2.8	7.58	28-Aug-23	28-Aug-23
25-Aug-23	DGT SW1 853	2700	<5	1.5	7.72	12-Sep-23	12-Sep-23
29-Aug-23	DGT SW1 854	2700	<5	2	7.76	12-Sep-23	12-Sep-23
01-Sep-23	DGT SW1 855	2700	<5	7.8	8.08	12-Sep-23	12-Sep-23
05-Sep-23	DGT SW1 856	2700	<5	1.2	7.86	12-Sep-23	12-Sep-23
10-Sep-23	DGT SW1 857	2700	<5	1.1	7.7	18-Sep-23	29-Sep-23
14-Sep-23	DGT SW1 858	2700	<5	2	7.35	21-Sep-23	29-Sep-23
17-Sep-23	DGT SW1 859	2700	<5	1.75	7.97	22-Sep-23	29-Sep-23
22-Sep-23	DGT SW1 860	2700	<5	1.5	7.12	29-Sep-23	29-Sep-23
27-Sep-23	DGT SW1 861	2700	<5	2.34	7.79	9-Oct-23	12-Oct-23
04-Oct-23	DGT SW1 862	3000	<5	3	7.58	12-Oct-23	12-Oct-23
07-Oct-23	DGT SW1 863	2700	<5	3	7.83	19-Oct-23	30-Oct-23
13-Oct-23	DGT SW1 864	2700	<5	1	7.76	19-Oct-23	30-Oct-23
18-Oct-23	DGT SW1 865	2700	<5	1.7	7.87	30-Oct-23	30-Oct-23
24-Oct-23	DGT SW1 866	2700	<5	0.7	7.74	6-Nov-23	17-Nov-23
28-Oct-23	DGT SW1 867	2700	<5	2	7.86	6-Nov-23	17-Nov-23
02-Nov-23	DGT SW1 868	3000	<5	2.5	7.57	10-Nov-23	17-Nov-23
05-Nov-23	DGT SW1 869	3000	<5	14	8.03	13-Nov-23	17-Nov-23
09-Nov-23	DGT SW1 870	2700	<5	1	7.96	17-Nov-23	17-Nov-23

EPA License Number: 4458

Licensee:

SUEZ WATER PTY LIMITED

PO BOX 6059

WETHERILL PARK NSW 2164

POINT 2 Monthly Summary

Note: does not include any monitoring conducted prior to 31 March 2012.

Special Frequency 1 means <15 days prior to discharge; and

Special Frequency 2 means <10 days prior to discharge

Month	Pollutant	Units of Measure	Monitoring Frequency	No. of Time Measured During Current Month	Min. Value	Average value	Max. Value	100 percentile Concentration Limit
Jun-12	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	<4	<4	<4	20
	Manganese	milligrams per litre	Special Frequency 2		0.063	0.063	0.063	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		5	5	5	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		5	5	5	50
	Zinc	milligrams per litre	Special Frequency 2		0.0036	0.0036	0.0036	N/A
	pH	pH	Special Frequency 2		7.57	7.57	7.57	6.5-8.5
Apr-15	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	3	3	3	20
	Manganese	milligrams per litre	Special Frequency 2		0.108	0.108	0.108	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		5.4	5.4	5.4	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		16	16	16	50
	Zinc	milligrams per litre	Special Frequency 2		0.006	0.006	0.006	N/A
	pH	pH	Special Frequency 2		7.39	7.39	7.39	6.5-8.5
Jan-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	<2	<2	<2	20
	Manganese	milligrams per litre	Special Frequency 2		1.18	1.18	1.18	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		7.4	7.4	7.4	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		10	10	10	50
	Zinc	milligrams per litre	Special Frequency 2		0.018	0.018	0.018	N/A
	pH	pH	Special Frequency 2		7.47	7.47	7.47	6.5-8.5
Jun-16	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	4	4	4	20
	Manganese	milligrams per litre	Special Frequency 2		0.134	0.134	0.134	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		9.2	9.2	9.2	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		17	17	17	50
	Zinc	milligrams per litre	Special Frequency 2		0.009	0.009	0.009	N/A
	pH	pH	Special Frequency 2		7.48	7.48	7.48	6.5-8.5
Mar-17	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	<2	<2	<2	20
	Manganese	milligrams per litre	Special Frequency 2		1.59	1.59	1.59	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		9.8	9.8	9.8	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		28	28	28	50
	Zinc	milligrams per litre	Special Frequency 2		0.017	0.017	0.017	N/A
	pH	pH	Special Frequency 2		7.7	7.7	7.7	6.5-8.5
Jun-19	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	3	3	3	20
	Manganese	milligrams per litre	Special Frequency 2		0.404	0.404	0.404	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		4.1	4.1	4.1	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		1	1	1	50
	Zinc	milligrams per litre	Special Frequency 2		0.005	0.005	0.005	N/A
	pH	pH	Special Frequency 2		7.5	7.5	7.5	6.5-8.5
Feb-20	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	3	3	3	20
	Manganese	milligrams per litre	Special Frequency 2		0.623	0.623	0.623	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		8.1	8.1	8.1	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		5	5	5	50
	Zinc	milligrams per litre	Special Frequency 2		0.005	0.005	0.005	N/A
	pH	pH	Special Frequency 2		7.68	7.68	7.68	6.5-8.5
Oct-20	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	4	4	4	20
	Manganese	milligrams per litre	Special Frequency 2		0.883	0.883	0.883	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		1.8	1.8	1.8	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		1	1	1	50
	Zinc	milligrams per litre	Special Frequency 2		0.008	0.008	0.008	N/A
	pH	pH	Special Frequency 2		7.75	7.75	7.75	6.5-8.5

Apr-21	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	12	12	12	20
	Manganese	milligrams per litre	Special Frequency 2		2.97	2.97	2.97	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		12.3	12.3	12.3	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		13	13	13	50
	Zinc	milligrams per litre	Special Frequency 2		0.005	0.005	0.005	N/A
	pH	pH	Special Frequency 2		7.13	7.13	7.13	6.5-8.5

Dec-21	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	10	10	10	20
	Manganese	milligrams per litre	Special Frequency 2		<0.001	<0.001	<0.001	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		13.8	13.8	13.8	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		8	8	8	50
	Zinc	milligrams per litre	Special Frequency 2		0.077	0.077	0.077	N/A
	pH	pH	Special Frequency 2		7.39	7.39	7.39	6.5-8.5

Feb-22	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	11	11	11	20
	Manganese	milligrams per litre	Special Frequency 2		1.77	1.77	1.77	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		13.7	13.7	13.7	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		17	17	17	50
	Zinc	milligrams per litre	Special Frequency 2		<0.005	<0.005	<0.005	N/A
	pH	pH	Special Frequency 2		7.31	7.31	7.31	6.5-8.5

Aug-22	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	2	2	2	20
	Manganese	milligrams per litre	Special Frequency 2		0.017	0.017	0.017	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		0.4	0.4	0.4	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		4.5	4.5	4.5	50
	Zinc	milligrams per litre	Special Frequency 2		<0.005	<0.005	<0.005	N/A
	pH	pH	Special Frequency 2		7.95	7.95	7.95	6.5-8.5

Oct-22	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	3	3	3	20
	Manganese	milligrams per litre	Special Frequency 2		3.8	3.8	3.8	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		6.8	6.8	6.8	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		15	15	15	50
	Zinc	milligrams per litre	Special Frequency 2		<0.005	<0.005	<0.005	N/A
	pH	pH	Special Frequency 2		7.37	7.37	7.37	6.5-8.5

Feb-23	Biochemical oxygen demand	milligrams per litre	Special Frequency 1	1	8	8	8	20
	Manganese	milligrams per litre	Special Frequency 2		2.87	2.87	2.87	N/A
	Nitrogen (total)	milligrams per litre	Special Frequency 2		41.4	41.4	41.4	N/A
	Oil and Grease	milligrams per litre	Special Frequency 2		<5	<5	<5	10
	Total suspended solids	milligrams per litre	Special Frequency 2		31	31	31	50
	Zinc	milligrams per litre	Special Frequency 2		<0.005	<0.005	<0.005	N/A
	pH	pH	Special Frequency 2		7.33	7.33	7.33	6.5-8.5

EPA License Number: 4458

Licensee:

SUEZ WATER PTY LIMITED

PO BOX 6059

WETHERILL PARK NSW 2164

POINT 2 Obtained Data

Note: does not include any monitoring conducted prior to 31 March 2012.

Date Sampled	DGT Sample No.	Biochemical Oxygen Demand (mg/L)	Manganese (mg/L)	Nitrogen Total (mg/L)	Oil & Grease (mg/L)	Total Suspended Solids (mg/L)	Zinc (mg/L)	pH (pH)	Date Obatined	Date Published
12-Jun-12	DGT SW2 027	<4	0.063	5	<5	5	0.0036	7.57	20-Jun-12	5-Jul-12
29-Apr-15	DGT SW2 028	3	0.108	5.4	<5	16	0.006	7.39	8-May-15	8-May-15
07-Jan-16	DGT SW2 029	<2	1.18	7.4	<5	10	0.018	7.47	15-Jan-16	18-Jan-16
08-Jun-16	DGT SW2 030	4	0.134	9.2	<5	17	0.009	7.48	16-Jun-16	17-Jun-16
01-Mar-17	DGT SW2 031	<2	1.59	9.8	<5	28	0.017	7.7	9-Mar-17	9-Mar-17
24-Jun-19	DGT SW2 032	3	0.404	4.1	<5	1	0.005	7.5	30-Jun-19	01-Jul-19
10-Feb-20	DGT SW2 033	3	0.623	8.1	<5	5	0.005	7.68	17-Feb-20	19-Feb-20
16-Oct-20	DGT SW2 034	4	0.883	1.8	<5	1	0.008	7.75	23-Oct-20	3-Nov-20
13-Apr-21	DGT SW2 035	12	2.97	12.3	<5	13	0.005	7.13	19-Apr-21	30-Apr-21
29-Nov-21	DGT SW2 036	10	<0.001	13.8	<5	8	0.077	7.39	9-Dec-21	10-Dec-21
28-Feb-22	DGT SW2 037	11	1.77	13.7	<5	17	<0.005	7.31	7-Mar-22	8-Mar-22
31-Aug-22	DGT SW2 038	2	0.017	0.4	<5	4.5	<0.005	7.95	12-Sep-22	23-Sep-22
6-Oct-22	DGT SW2 039	3	3.8	6.8	<5	15	<0.005	7.37	14-Oct-22	24-Oct-22
20-Feb-23	DGT SW2 040	8	2.87	41.4	<5	31	<0.005	7.33	27-Feb-23	27-Feb-23